



# DCU300M1224

# DCU300M1224S



## DC-UPS User's Manual

## Table of Contents

1	Preliminary Notes.....	3	10.1	Types of Batteries.....	20
1.1	Symbols .....	3	10.2	Battery charging .....	20
1.2	Safety and Warning Notes.....	4	10.3	Charging Phases .....	21
2	Installation Check List.....	5	10.4	Battery Tester function.....	22
3	Description .....	6	10.5	Battery replacement.....	22
3.1	General.....	6	11	Signaling and communication.....	23
3.2	Layout .....	7	11.1	LED signals.....	23
3.3	Dimensions.....	8	11.2	Alarm contacts.....	23
3.4	Block Diagram.....	9	11.3	MODbus-RTU.....	23
4	Installation.....	10	12	Output Configurations.....	25
4.1	Normal Mounting Position.....	10	12.1	Standard Output configuration .....	25
4.2	Mounting the DC-UPS.....	10	12.2	Redundancy Output configuration.....	25
4.3	Removing the DC-UPS.....	10	12.3	Series Output configuration .....	25
5	Connection.....	11	13	Derating.....	27
5.1	Wiring Cables Cross-sections .....	11	13.1	Ambient Temperature Derating.....	27
5.2	Mains Input .....	11	13.2	Elevation Derating .....	27
5.3	Load Output.....	12	14	Technical Data .....	28
5.4	Battery Output.....	12			
5.5	Alarm contacts connection.....	13			
5.6	SBS Temperature Smart Battery Sensor connection .....	13			
5.7	Data Link Connection .....	14			
6	DC-UPS Configuration.....	15			
6.1	Output Voltage Setting .....	15			
6.2	Maximum Charge Current Setting ..	15			
6.3	Battery Type Setting .....	15			
6.4	Buffer Time Setting.....	16			
6.5	Fast Charge.....	17			
6.6	Life test.....	17			
6.7	Setting Power Supply mode .....	17			
6.8	Setting Rest Mode .....	18			
6.9	Load output Remote On-Off on Data Link.....	18			
7	Operation Modes .....	18			
7.1	Standby Mode.....	18			
7.2	Backup Mode .....	18			
7.3	Power Supply Mode .....	19			
8	Power Boost .....	19			
9	Battery Start .....	19			
10	Battery Management.....	20			

# 1 Preliminary Notes

## 1.1 Symbols

Throughout this document, the following symbols will be used to display instructions and possible dangers:

**NOTE**

When this symbol appears, along with the "NOTE" word, the reader is notified about situation which may cause damage or malfunction to the device, hardware/software, or surrounding property.



When this symbol appears, the reader is provided with additional information or referred to detailed sources of information.



When this symbol appears, safety hazards are involved. Extreme care must be taken as potential personal injury hazards may occur.  
Comply with all safety measures indicated in the following text to avoid potential personal injuries.

Different categories of personal injuries are indicated by different signaling.

**WARNING**

This word implies a hazardous situation which, if not prevented, could result in death or serious injury.

**CAUTION**

This word implies a hazardous situation which, if not prevented, could result in minor or moderate injury.

## 1.2 Safety and Warning Notes



### **WARNING: Electric shock risk!**

- This device must be properly installed, started up, and operated only by qualified technicians.
- Always verify no voltage is present before beginning to work.
- Ensure correct wiring connection and safety regulation compliance to protect against electric shock.
- Connect the protection conductor terminal "PE" with ground.
- Cover terminals' area after installation to avoid accidental contacts with live parts (e. g., installation in control cabinet).



### **WARNING: Explosion Hazard**

Do not disconnect Equipment unless power has been switched off or the area is known to be non-hazardous



### **CAUTION**

Before servicing, disconnect both Mains and the energy storage to de-energize the unit.



### **CAUTION: Fire Prevention**

- Do not place flammable or exploding material nearby the device.
- To reduce the risk of fire, connect only to a circuit provided with a maximum branch circuit overcurrent protection in accordance with the Norms
- To reduce the risk of fire, replace only with same type and rating of fuse.



### **CAUTION: Hot surface**

- Both the ambient temperature and heat losses due to the load operation may overheat the device housing surfaces.
- Ensure sufficient convection (minimum gap above/below: 50 mm), sides 10 mm.



### **NOTE: Battery Connections**

When batteries are being connected, check for correct polarity. Make sure not to short circuit the battery terminals.



### **NOTE: Wiring selection**

- Copper cables must be used for operating temperatures above 75 °C.
- Refer to the associated table for the connection parameters, such as the necessary stripping length for the wiring with and without ferrule (see section Wire cross sections).



### **NOTE: General Installation Notes**

- National safety and accident prevention guidelines must be followed according to UL508 or UL60950.
- Assembly and electrical installation must correspond to the state of the art.
- The DC-UPS is a built-in device. The protection class of the device is IP20. It is meant to be installed in a clean and dry environment.
- Protect the device against foreign bodies penetrating it, e.g., paper clips or metal parts.
- The device must be installed in a control cabinet that can be locked and only opened by specialist staff.
- Vertical mounting is the normal and only authorized mounting position
- Observe mechanical and thermal limits.



### **NOTE: Protections Selection**

- Install a switch/circuit breaker close to the device at the Mains input, Load output and at the battery terminals which are labeled as the disconnecting device for this device.
- Ensure that the primary-side wiring and secondary-side wiring are the correct size and have sufficient fuse protection.
- Do not disconnect the fuse and/or battery connection when in hazardous locations.
- Use current-limited source or suitable fuse.
- The switching outputs are active outputs according to SELV. These may only be operated on permitted SELV circuits.



- The device is maintenance-free. Repairs may only be carried out by the manufacturer. The warranty no longer applies if the housing is opened.
- The device may only be used for its intended use.
- Improper use invalidates the device protection.
- Keep these instructions in a safe place – it contains important safety notes which must be observed during installation and maintenance of the DC-UPS devices and batteries.

## 2 Installation Check List

Please carefully follow this check list during installation. We suggest printing, fill out and file it as installation report. Add notes as felt necessary.

Figure 2.1 - Installation Device Check List

Device: DCU300M1224S		Ref:		
Item	Action	Setting device Reference	✓	Notes
1	Read Safety and Warning notes	Chapt. 1		
2	<b>Set Output Voltage, 12V or 24V</b>	<b>Dipswitch 1</b>		
3	Set Maximum Charge Current	Selector 7, Chapt. 6.2		
4	Mount the DC-UPS	Chapt. 4		
5	Wire the DC-UPS	Chapt. 5.1		
5.1	Wire Mains	Chapt. 5.2		
5.2	Wire Load	Chapt. 5.3		
5.3	Wire Battery	Chapt. 5.4		
5.4	Wire Alarm contacts	Chapt. 5.5		
5.5	Wire SBS Temperature sensor	Chapt. 5.6		
5.6	Wire Data Link	Chapt. 5.7		
6	Configure the DC-UPS			
6.1	Set Battery Type	Dipswitch 3-4-5, Chapt. 6.3		
6.2	Set Buffer Time	Selector 6, Chapt. 6.4		
6.3	Enable or disable Fast Charge	Dipswitch 7, Chapt. 6.5		
6.4	Enable or disable Life Test	Dipswitch 8, Chapt. 6.6		
6.5	Enable or disable Rest Mode	Dipswitch 6, Chapt. 6.8		

## 3 Description

### 3.1 General

Congratulation for choosing an Aris Power innovative, high performance and safety power product. Install it in your application to achieve higher reliability and extended lifetime.

**DCU300M1224S** is a **300 W DC-UPS** belonging to the DCU Series, AC to DC Uninterruptible Power Supply systems. Its mission is providing Power Security to critical DC loads. For flexibility of use, it features selectable output voltage, 12 Vdc or 24 Vdc, via dip switch. Input is very flexible and can be AC or DC

Main Features - Designed following a mains-connected, on-line, All-in-One architecture, the device contains:

- Power supply + Back-up Module + Battery Charger + Battery Monitoring + Battery Tester, all packaged in one box.
- Its wide input range, makes it suitable for connection to mains with 115–230-277 Vac single-phase voltage rating or 110-240 Vdc
- Load-first, Dynamic Load/Battery power sharing logic
- In Power Boost Mode it can deliver up to 4 times the rated current. It is therefore uniquely suitable to backing up DC loads with high inrush current
- Buffer time setting of load backup
- Manual Battery start-up with no mains via push button
- Full set of protections. Both Load and Battery outputs are protected against overload and short circuit. On safety grounds, the **battery output is disabled when the battery is disconnected**
- Adjustable maximum charging current to protect the battery against overcurrent damages
- Remote alarms via 3 dry relay contacts
- Standby/Backup
- Battery Low & Common Fault
- Rectifier Failure
- Smart Battery Sensor (SBS) for temperature compensation via USB port
- Battery management is performed by Aris Power **BattSafe**, a comprehensive battery management firmware. BattSafe includes:
  - Universal Charger with factory-set charging curves for the most common battery types: Vented Lead Acid, VRLA, Valve Regulated AGM or Gel Lead Acid, Ni-Cd, Li-Io
  - flat batteries which are not irreversibly damaged can be recovered
  - real time diagnostic during installation, preventing installation errors
  - continuous battery monitoring during operation, minimizes the risk of battery damage and allows a fully safe operation while keeping battery in permanent connection with the DC-UPS. Extended battery life is the result.
  - Device and system faults are also detected by auto-diagnostic features.
  - Battery Tester - Life test can be activated manually through a dedicated push button, to facilitate maintenance checks
  - All status and faults signals are shown on the front panel LEDs.
  - Data Link Communication (DLC), on devices with this feature, allows availability of status and faults signals also in remote mode.

## 3.2 Layout




Figure 3.1 – Device layout

N.	Description	N.	Description
1	INPUT VOLTAGE TERMINALS	9	BATTERY STATUS LED
2	QR CODE LINK TO ONLINE USER'S MANUAL	10	FAULT LED
3	CAN BUS/MODE BUS RJ45 CONNECTOR 1	11	MAINS/BACKUP LED
4	CAN BUS/MODE BUS RJ45 CONNECTOR 2	12	ALARMS PUSH-IN TERMINALS
5	BATTERY START/TEST PUSH BUTTON	13	BATTERY OUTPUT TERMINALS
6	BUFFER TIME SELECTOR	14	LOAD OUTPUT TERMINALS
7	CHARGE CURRENT TRIMMER	15	SENSOR FOR BATTERY TEMPERATURE COMPENSATION (UART CONNECTOR)
8	FUNCTIONS DIP-SWITCHES		

### 3.3 Dimensions




Figure 3.2 – Side and front views

### 3.4 Block Diagram




Figure 3.3 - Device block diagram. Black continuous lines represent power connections, dashed lines indicate functional links

Block	Description	Block	Description
	Buffer Time Selector		Rectifier
	Max Current Setting		Regulator
	Electrically Isolated Signal Transmission		RJ45 Serial Communication
	Fuse		Smart Battery Sensor UART USB
	LED - Battery		Safety Switch
	LED - Fault		Supply Swapping Switch
	LED - Mains/Backup		Temperature Protection Sensor
	Microcontroller		Transformer
	Battery Start / Test Push Button		

## 4 Installation

### 4.1 Normal Mounting Position

The device can be snapped onto all DIN rails according to EN 60715 and should only be mounted in the normal mounting position, as shown in Figure 4.1.




Figure 4.1 – Device mounting position



#### NOTE

- The device must be installed in a control cabinet that can be locked and only opened by specialist staff.
- The device must be installed at least 10 mm apart from all other devices to allow proper ventilation. While in operation, be aware that the temperature of the external case can become very high depending on load/battery current and ambient temperature

### 4.2 Mounting the DC-UPS

To mount the device, proceed as follows:

1. In the normal mounting position, the device is mounted on the DIN rail from above. Make sure that the DIN rail bracket is in the correct position above the DIN rail.
2. Place a suitable screwdriver on the tab of the DIN rail bracket.
3. Pull the tab down by lifting the screwdriver.
4. Press the device down until the bracket snaps into place
5. Check that the device be securely fastened onto the DIN rail




Figure 4.2 -Mounting the device

### 4.3 Removing the DC-UPS

To remove the device, proceed as follows:

1. Place the screwdriver on the tab of the DIN rail bracket
2. Unlock the tab from the DIN rail by lifting the screwdriver.
3. Carefully pull the lower part of the device forward so that the tab slides back into the initial position.
4. Remove the device from the DIN rail




Figure 4.3 – Removing the device

## 5 Connection

### 5.1 Wiring Cables Cross-sections

For connection use copper wires only, suitable for minimum 75°C. Wiring terminals shall be marked according to best industry practice to indicate proper connection to and from the DC-UPS.

Table 1 - Cable cross-sections to be used for wiring

Connect to	Terminal Type	Solid (mm <sup>2</sup> )	Stranded (mm <sup>2</sup> )
<b>Mains</b>	Screw	0.2 – 4.0	0.2 – 4.0
<b>Load</b>	Screw	0.2 – 4.0	0.2 – 4.0
<b>Battery</b>	Screw	0.2 – 4.0	0.2 – 4.0
<b>Signals</b>	Push in	0.2 – 1.0	0.2 – 1.0

Connect to	AWG	Torque (Nm)	Stripping Length (mm)
<b>Mains</b>	26 - 12	0.5 - 0.6	7
<b>Load</b>	26 - 12	0.5 - 0.6	7
<b>Battery</b>	26 - 12	0.5 - 0.6	7
<b>Signals</b>	24 - 20	0.5 - 0.6	11

### 5.2 Mains Input

AC or DC mains input is connected via the terminals at the bottom of the DC-UPS.




Figure 5.1 - Mains input connection

#### 5.2.1 Primary side protection

To switch on / off the device, a proper disconnection device must be installed on the mains connection. This function can be performed by the recommended primary-side line protection, either a delayed Fuse or an MCB, curve C.

The device is also protected against device faults. by an internal fuse.




Figure 5.2 – Primary side protection



If, due to a device fault, the internal fuse trips, the device must not be opened. It must be returned for factory inspection. Un-authorized opening or repairing of the device is not allowed and would void the guarantee coverage.

#### 5.2.2 Mains connection

The DC-UPS can be operated on AC single-phase and DC power grids in accordance with the rated input voltage. Connection is via the input L/+, N/-, PE terminals.




Figure 5.3 – Mains connection

## 5.3 Load Output

Buffered loads are connected to the DC-UPS on the LOAD output terminals. There are two plus (" + ") and two minus (" - ") terminals available. Use a 3 mm flat-head screwdriver.




Figure 5.4 -Load connection

Load output cables must be properly dimensioned for the maximum output current. They should also have a large cross section to keep voltage drop as low as possible.

## 5.4 Battery Output

The BBX battery module or customer own battery module is connected to the DC-UPS via the first two terminals in the upper terminals area. Use a 3 mm flat-head screwdriver.

Battery output cables must be properly dimensioned for the maximum output current. They should also have a large cross section to keep voltage drops as low as possible





Figure 5.5 – Battery connection

Connection to the Battery must be done according to the following instructions:

1. The DC-UPS must be switched off before connecting the battery
2. Install the Battery Box as close as possible to the DC-UPS
3. Open the front cover of the housing.
4. Remove the fuse (see Figure 5.5a).
5. Connect the wiring between the DC-UPS and the Battery Box
6. Insert back the fuse (see Figure 5.5b).
7. Close the front cover
8. Secure the housing to prevent it from being opened.
9. Power up the DC-UPS






Figure 5.6 – BBX Battery box – a) Removing and b) Inserting fuse



#### WARNING

- When connecting the batteries take note of the polarity.
- Do not short circuit the pole terminals.
- The batteries are maintenance free and may not be opened.



#### NOTE

**Risk of short circuit** - When installing or replacing the battery, the fuse of the battery module must be removed. This will prevent the risk of short circuit and ensure safety for the operator.



#### NOTE

Before storing Battery modules, note the latest recharge or recharge it, if necessary.

## 5.5 Alarm contacts connection

The DC-UPS is equipped with three built-in alarms, as follows:

- Mains/Backup
- Battery Fault
- Rectifier Failure

The three alarms are on dry change-over relay contacts and are brought to push-in terminals on the front of the device.

Connect the push-in terminals using wiring cables according to above given instructions.





Figure 5.7 – Alarm contacts connection

## 5.6 SBS Temperature Smart Battery Sensor connection

The SBS sensor is necessary when battery temperature compensation of charging voltage is required by the norms.

Table 2 - Battery Charging Voltage Compensation as a function of Temperature deviation from 20 °C (\*)

Parameters	Fast Charge	Float charge
$\frac{\Delta U}{^{\circ}\text{C} \cdot \text{Cell}}$	±5 mV	±3 mV
Temperature range	-8 °C to +60 °C	-20 °C to +60 °C
$\frac{\Delta U}{\text{Cell}}$	+140 mV / -200 mV	+120 mV / -120 mV
Reference temperature	+20 °C	+20 °C

(\*) These values do not apply to Li-Ion and NiCd batteries

The DC-UPS is designed to perform temperature compensation battery charging voltage in compliance with the specifications of EN54-4 fire protection norm or other international equivalent norms, as follows

### 5.6.1 Customer selected battery pack

To activate this function, locate the UART connector on top of the device. Connect the SBS001 cable (separate article, not included) to the device and to the battery. Once connected, the device will self-configure to perform battery voltage temperature compensation.

### 5.6.2 Aris Power BBX battery box

In case a BBX with built-in Temperature Smart Battery Sensor is designed in the system, to activate this function, locate the UART connector on top of the device. Connect the SBS002 cable (separate article, not included) to the device and to the customer own battery pack. Once connected, the device will self-configure to perform battery voltage temperature compensation.




Figure 5.8 - SBS001 Temperature Smart Battery Sensor with cable for customer battery pack






Figure 5.9 - Smart Battery Sensor Scheme

## 5.7 Data Link Connection

To activate this function, locate the RJ45 connectors on the front of the device. Connect the DLK001 cable (separate article, not included) to the device and to the Custom logic unit. The device will self-configure.



a



b

Figure 5.10 – Data Link (a) connectors and (b) DLK001 connecting cable

## 6 DC-UPS Configuration

Before powering on, the DC-UPS must be configured via the selectors and dipswitches on the front panel.

### 6.1 Output Voltage Setting

This is a Selectable Output Voltage DC-UPS device, 12 Vdc or 24 Vdc.

Before powering on the device, it is fundamental to select the correct output voltage to match load and battery rated voltage.



#### WARNING

- Special care must be paid when setting this parameter since a wrong configuration may cause damages to load and battery.
- Do not change dip switch 1 position while the device is energized. It might cause damages to load and battery. If in need to do so, power off the device first.

Factory setting is always 12 Vdc, the lowest of the two featured voltages. This corresponds to top dip switch n. 1 in position A.




Figure 6.1 -Setting Output Voltage

In case 24 Vdc is required, before powering on the device, move dip switch n. 1 to position B.

### 6.2 Maximum Charge Current Setting

It is a key setting in enabling a safe and extended battery lifetime. Adjustment of the maximum Charge Current selector allows to protect the battery from excessive charging currents.

To determine this value, refer to the battery manufacturer's datasheet. If this is not available, consider a maximum charge current in the range between 1/10 and 1/8 of battery rated capacity given in Ah. (Example: for a 10 Ah battery = 1.0 – 1.3 A). This approximate value is suitable for Lead Acid and NiCd but not necessarily for other types of batteries.




Figure 6.2 – Maximum Charge Current Setting

To select the desired maximum charge current, rotate the corresponding selector (7). Current can be set between 10-100% of DC-UPS nominal current. Factory setting is 10%.



Battery charging current is capped by the maximum charging current set on the selector (7).

### 6.3 Battery Type Setting

This device allows different battery charging operations based on the installed battery type. To select the correct type, the 3<sup>rd</sup>, 4<sup>th</sup> and 4<sup>th</sup> dip switch must be configured according to the following table.



#### WARNING

Switch off the system before selecting battery type on the Dip Switch.




Figure 6.3 – Battery Type setting

Table 3 - Battery type selection via Dipswitch

Dip Switch Position	Battery Type				
	Vented Lead	VRLA AGM Lead	VRLA Gel Lead	Li-ion	Ni-Cd, Ni-Mh
<b>Dip 3</b>	A	B	B	A	B
<b>Dip 4</b>	A	B	A	B	A
<b>Dip 5</b>	A	A	B	B	A

Factory setting is always Vented Lead. This corresponds to dip switch n. 3, 4, 5 in position A.

## 6.4 Buffer Time Setting

Different buffer times can be set via the Buffer Time selector on the device (6). Ten positions are available. The selector default factory set position is set on “10”, meaning that loads will be fed until the battery voltage reaches the Low Voltage Disconnect (LVD) value. Below this value, the device will autonomously switch off to prevent unnecessary discharge and consequent battery shorter life. In case the buffer time switch is set at a different position, the device will switch off after the corresponding time has elapsed, as shown in the table below.

Rotating the selector in clockwise direction will result in an increased buffer time.



Figure 46.4 – Buffer Time setting

Table 4 - Buffer Time selection

Selector Position	Buffer Time (minutes)
1	0.5
2	2
3	5
4	10
5	15
6	20
7	30
8	45
9	60
10	∞

If the buffer time rotary switch is set on the default position ∞, the battery will supply the load until it reaches the Low Voltage Disconnect (LVD) threshold.



The rotary selector switch (6) must be set using a suitable screwdriver.

The maximum Buffer Time duration depends on the battery capacity rating and status of charge. Assuming backup occurs when the battery is fully charged, the times given in the table below can be used as reference.

Table 5 - Typical max buffer time with Aris Power Battery Boxes BBX Series, 24 V

Load Current (A)	Minutes		
	BBX012 024 1.2 Ah	BBX034 024 3.4 Ah	BBX07 2024 7.2 Ah
1.5	20	60	200
3	8	30	120
5	3	15	55
7.5	2	10	30
10	NA	7	20
15	NA	NA	9
20	NA	NA	7

Load Current (A)	Minutes	
	BBX120024 12.0 Ah	100 Ah
1.5	400	NA
3	240	NA
5	100	NA
7.5	60	NA
10	45	1200
15	20	400
20	12	240

## 6.5 Fast Charge

To speed up the battery charging process, the Fast Charge function can be selected, hence applying the bulk voltage on the battery. To enable this function, the corresponding dip-switch n. 7 must be set at position B.




Figure 6.5 – Fast Charge setting

Factory setting is Fast Charge OFF. This corresponds to dip switch n. 7 in position A

## 6.6 Life test

The Life test function allows to perform a diagnosis of the battery and to get notified whether the battery is in a good or a bad condition.




Figure 6.6 – Life Test Enable/Disable

Factory setting is Life Test OFF. This corresponds to dip switch n. 8 in position A.

## 6.7 Setting Power Supply mode

This function allows the device to supply energy while the battery is disconnected. To enable this function, place the corresponding dipswitch to the right. Present on all DC-UPS and battery charging devices but necessary and factory configured on Battery Charging devices only.




Figure 6.7 -Power supply mode setting

Factory setting is Power Supply OFF. This corresponds to dip switch n. 8 in position A.

## 6.8 Setting Rest Mode

To extend battery life, the Rest option can be selected. When reaching the Float state, the battery will disconnect for a time frame depending on the battery type. Throughout this time period, the voltage on the battery output terminals will be monitored. Once the voltage drops below a predefined threshold, the battery will be reconnected. To enable this function, place the corresponding dipswitch to the B position.




Figure 6.8 – Rest Mode setting

Factory setting is Rest Mode OFF. This corresponds to dip switch n. 6 in position A

## 6.9 Load output Remote On-Off on Data Link

This feature allows to switch on/off the output to the load from remote. It requires Modbus connection.

# 7 Operation Modes

## 7.1 Standby Mode

This is the default status of the device. When mains is present and the battery is present and connected, the device sets automatically to Standby Mode.




Figure 7.1– Standby Mode

In this mode, load output voltage follows the battery voltage. Current sharing between load and battery is autonomously managed by the device, always giving priority to load demand.

### Signaling

With mains present, the Mains/Backup LED (11) will be set on a steady green color.

### Overload and Short Circuit protection

If the load demand increases, taking the current value up to its short circuit threshold, the short circuit protection will trigger. Both Overload and Short circuit conditions will be shown by the common FAULT LED and status change of F Relay output.

## 7.2 Backup Mode

When the battery is connected and charged, in case mains either fails, falls below a threshold value (50% of the rated input voltage) or is anyhow not present, the device sets automatically to Backup Mode. The battery is immediately connected to the load output, without any interruption.




Figure 7.2 – Backup Mode

From this moment on, the battery is entirely in charge of supplying power to the load. During this mode, load output voltage will follow battery voltage while it discharges. The current going to the load is limited in time according to the battery status of charge.

### Signaling

This condition is shown by a Orange light on the Mains/Backup LED and a status change of (M) relay output.

## Overload and Short Circuit Protection

While in Backup the load and the DC-UPS will be protected against overload and short circuit as in the above Table. Both Overload and Short circuit conditions will be shown by the common FAULT LED and status change of F Relay output.

## 7.3 Power Supply Mode

When mains is present and the battery is either absent, faulty, or disconnected, the device turns into Power Supply Mode. In this case, load output voltage is stabilized at the selected rated value. Available output current is completely absorbed by the load.




Figure 7.3 – Power Supply Mode

## Signaling

This condition is shown by a RED light on the FAULT LED and status change of F Relay output.

## Overload and short circuit protection

During Power Supply mode, if the load demand increases, the DC-UPS can take an overload up to 20% of its nominal current. This corresponds to the short circuit threshold. Above this value, the short circuit protection will trigger, as shown in the figure below. Both Overload and Short circuit conditions will be shown by the common FAULT LED and status change of F Relay output

## 8 Power Boost

Since the priority task of the DC-UPS is ensuring the continuity of load power supply, the current delivered to the battery may vary to accommodate load demand first.

The current to the load will follow the demand of the load. When the load demands more than rated, Power Boost is enabled. Under this condition, battery charging will stop or be limited, and the battery will start instead contributing to the load power supply. The total current going to the load is limited in time according to overload current intensity.

During Standby mode, part of the Boost power will come from the mains via the device power supply circuit, part will come from the battery.

During Backup mode all Boost power will come from the battery.

Unless the device is in Power Supply mode (i.e. without battery), when Boost is equal to +20% of  $I_R$  during the other modes, if the battery is fully functional, Power boost will be as follows.

Table 6 - Power Boost while in Standby or Backup modes.

Load Current	12 V	24 V
Rated	15 A	10 A
Continuous	20 A	15 A
< 30 sec	25 A	20 A
< 15 sec	30 A	25 A
< 5 sec	35 A	30 A

## 9 Battery Start

When mains voltage is not available, and the load must be powered up from the battery, the DC-UPS must first be started using the Battery Start push button ( 5 ).




Figure 9.1 -Battery Start (5)

Keeping the Battery Start button pressed for 2 s, the three LED will turn on in orange color, the DC-UPS will power-on

and power the load under the same conditions as in Backup Mode.

This is a facility particularly useful during commissioning if mains is not available to test load operation.

## 10 Battery Management

### 10.1 Types of Batteries

BATTSAFE firmware includes factory-set charging curves for the most common battery types: Vented Lead Acid, AGM and Gel Lead Acid, Ni-Cd, Li-Io.

Lead Acid batteries follows a 4-stage charging curve: IUoU (Bulk, Absorption, Float) plus Recovery stage for deeply discharged batteries.

Charging curves can be selected by dipswitch (see Chapt. 6.3). They can also be customized via Data Link.

Table 7 - Charging voltage for battery type

Battery Type	Charging Voltage (V/cell)	
	Float	Bulk
<b>Vented Lead</b>	2.23	2.4
<b>VRLA AGM Lead</b>	2.25	2.4
<b>VRLA Gel Lead</b>	2.3	2.4
<b>Li-ion</b>	3.45 <sup>1</sup>	3.65 <sup>1</sup>
<b>Ni-Cd, Ni-Mh</b>	1.40 <sup>2</sup>	1.50 <sup>2</sup>

Note: <sup>1</sup> 12 V : 4 cells, 24 V : 8 cells; <sup>2</sup> 12 V : 10 cells, 24 V : 20 cells, 48 V : 40 cells.



The Charge Current trimmer (7) allows to select the maximum charging current from the device to the battery. This is a critical setting to protect the battery

## 10.2 Battery charging

Battery management is performed by Aris Power BATTSAFE, a comprehensive battery management firmware based on algorithms for automatic and optimized battery charging.

BATTSAFE includes:

- Universal Charger with factory-set charging curves for the most common battery types: Vented Lead Acid, AGM and Gel Lead Acid, Ni-Cd, Li-Io
- flat batteries which are not irreversibly damaged can be recovered
- real time diagnostic during installation, preventing installation errors
- continuous battery monitoring during operation, to minimize the risk of battery damage and allow a fully safe operation while keeping battery in permanent connection with the DC-UPS. Extended battery life is the result.
- Device and system faults are also detected by auto-diagnostic features.
- Battery Tester - Life test can be activated manually through a dedicated push button, to facilitate maintenance checks
- All status and faults signals are shown on the front panel LEDs.
- Data Link Communication (DLC), on devices with this feature, allows availability of status and faults signals also in remote mode.

BATTSAFE can diagnose battery fault conditions, among them:

- Battery cells in short circuit
- Sulfated battery
- Reverse polarity connection
- Battery missing or disconnected
- Battery Life Test




Figure 10.1 – Battery Charging Curve

## 10.3 Charging Phases

All Lead-Acid battery charging curves share the same charging phases.

DCU operate as an Automatic multi-stage charger following a stabilized voltages and stabilized current IUoU curve. The 5 charging phases are identified by a flashing code on the Battery LED.

### 10.3.1 Recovery

This charging phase is used to recover deeply discharged batteries. During this phase, a constant current is applied to the battery. If the battery is still in good conditions the battery voltage will increase and eventually reach 1.67 V/cell (10 V at  $U_n=12$  V or 20 V at  $U_n=24$  V). Once reached this value the charge mode will automatically transfer to Bulk charge mode. The minimum duration of this phase is 5 s. Timeout is set at 120 min. If instead after 120 min the 1.67 V/cell level is not reached, this means that the battery cannot be recovered. The DCU will signal fault on the Fault LED and F Relay contact.

### 10.3.2 Bulk

The battery enters Bulk phase either after reaching 1.67 V/cell (10 V at  $U_n=12$  V or 20 V at  $U_n=24$ ) if coming from Recovery mode or after falling below 2.1 V/cell (12.6 V at  $U_n=12$  V or 25.2 V at  $U_n=24$  V) while in Float mode. During this charging phase the current is kept constant at its maximum value set on trimmer (7).

Once Bulk voltage is reached, the battery will enter in Absorption phase. The minimum duration of this phase is 5 s. Timeout is set at 900 min. After this time, charging will automatically transfer to Absorption charge mode.

### 10.3.3 Absorption

During this charging phase, with Fast Charge enabled, the voltage is set equal to 2.375 V/cell, while the current progressively decreases.

If Fast Charge is disabled, the voltage is instead set equal to 2.225 V/cell. This is the proper selection in case the Load does not accepts the Fast Charge voltage but only this lower voltage level. Simply

leave Fast Charge disabled on dipswitch (7).

Once the current falls below  $I_{max}/8$ , the battery waits for 9 s before entering Float charge mode.

Timeout is set at 300 min. After this time, the charge will automatically transfer to Float charge mode.

### 10.3.4 Float

During Float charge mode, voltage is set at the float voltage level selected by dipswitch for each battery type. This is the long-term condition under which the battery will be safely kept charged during Standby mode.

In case the battery becomes discharged below 2.1 V, the charge will automatically transfer back to Bulk charge mode.

During Float charge mode every 4 hours life test will be performed. If test proves positive, LED signaling and alarm contact will trigger for warning.

## 10.4 Battery Tester function

While in Float charge or when replacing the battery, the DCU battery output can be used as a Battery Tester. By pressing the Battery Start/Test push button for 10s, the DCU will run a full life test. The negative or positive result will be shown by a blinking code on the LEDs. If test indicates that the battery needs to be replaced, please see "Battery Replacement".

## 10.5 Battery replacement

Follow these instructions to replace batteries:

1. Switch off the device before replacing the battery
2. Open the front cover of the battery housing.
3. Remove the fuses (see Figure 10.2a).
4. Disconnect the battery wiring.
5. Remove the batteries.
6. Install the new batteries.

7. Connect the battery wiring.
8. Install the fuses (see Figure 10.2b).
9. Close the front cover
10. Secure the housing to prevent it from being opened.
11. Switch on the DC-UPS




Figure 10.2 – BBX Battery box – a) Removing and b) Inserting fuse



#### WARNING

- When re-connecting the batteries take note of the polarity.
- Do not short circuit the pole terminals.
- The batteries are maintenance free and may not be opened.



#### NOTE

When replacing batteries, always use new batteries from the same batch.

## 11 Signaling and communication

DCU is fully open device. It communicates via the three channels described below.

### 11.1 LED signals

Three LED indicators are available for visual monitoring of the DC-UPS on the device front. See layout.

- Mains/Backup LED (11)
- Fault LED (10)
- Battery LED (9)

Thank to blinking code, they provide full set of status and diagnostic information, very useful during installation and on-site inspection. For LED signaling and the corresponding states, please refer to the table below.




Figure 11.1 – Signaling LEDs communication

### 11.2 Alarm contacts

The DC-UPS is equipped with three built-in alarm contacts. They can be used to forward key alarms to higher-level control system, as follows:

- Mains/Backup (M)
- Fault (F)
- Rectifier Alarm (S)

The three alarms are on dry change-over relay contacts and are brought to push-in terminals on the front of the device. The signal alarm contacts are switched at device power up

and will return to rest status when the device is de-energized, according to fail-safe mode practice. For alarm contacts states, please refer to the table below.




Figure 11.2 – Alarm contacts communication

### 11.3 MODbus-RTU

The DC-UPS can communicate with a PLC or a higher-level controller via a serial port on the two RJ45 connectors. The interface is designed for MODBus-RTU communication protocol. The DC-UPS BATTSAFE firmware includes a full communication interface to allow remote monitoring and control of the system. The device is ready configured to enable communication. Please contact Customer Support for full infos on available set of parameters, communication protocol and Map of Registers.

















Figure 11.3 - Data Link communication

LEDs Signaling Meaning	LEDs											RELAYS		
	Mains/Backup (11)			Fault (10)				Battery (9)				Mains/Backup (M)	Fault (F)	Rectifier Failure (S)
	Red	Orange	Green	Red	Orange	Green	Notes	Red	Orange	Green	Notes			
Device off	○	○	○	○	○	○		○	○	○		OFF	OFF	OFF
Power-Init	○	●	○	○	●	○		○	●	○		ON	ON	ON
Recovery-charge	○	○	●	●	○	○		●	○	○	2 blink / 1 sec 	ON	ON	OFF
Bulk	○	○	●	○	○	●		○	●	○	1 blink / 1 sec 	ON	ON	ON
Absorption	○	○	●	○	○	●		○	●	○	1 blink / 2 sec 	ON	ON	ON
Float	○	○	●	○	○	●		○	○	●		ON	ON	ON
Reverse Polarity	○	○	●	●	○	○	1 pulse 	●	○	○		ON	OFF	OFF
Disconnected Battery	○	○	●	●	○	○	2 pulses 	●	○	○		ON	OFF	OFF
Wrong Battery Voltage	○	○	●	●	○	○	3 pulses 	●	○	○		ON	OFF	OFF
Float, cell in short circuit	○	○	●	●	○	○	4 pulses 	●	○	○		ON	OFF	OFF
Float, Life Test	○	○	●	●	○	○	5 pulses 	●	○	○		ON	OFF	OFF
Low Battery Voltage	○	○	●	●	○	○	6 pulses 	●	○	○		ON	OFF	OFF
Overload or Short circuit on load output	○	○	●	○	●	○	1 pulse 	○	○	○		ON	OFF	ON
Load Boost	○	○	●	○	●	○		○	○	○		ON	OFF	ON
Rectifier fail	○	○	●	○	●	○	3 pulses 	○	○	○		ON	OFF	ON
Wire High impedance	○	○	●	○	●	○	4 pulses 	○	○	○		ON	OFF	OFF
Back-up operation ok	○	●	○	○	○	○		○	○	●		OFF	OFF	ON
Battery almost discharged	○	●	○	○	○	○		○	●	○		OFF	ON	OFF
Battery fully discharged	○	●	○	○	○	○		●	○	○		OFF	ON	ON
Overload or Short circuit on load output during back-up	○	●	○	○	●	○	1 pulse 	○	○	○		ON	OFF	ON

Legend	Color	Green = All good    Orange = Warning    Red = Alarm		
	Status	 LED flashing	 LED on	 LED off

## 12 Output Configurations

Besides in Standard configuration described below, DC-UPSs of the same type can be connected in parallel configuration to achieve a desired redundancy level or increase totally available current.

DC-UPSs can also be connected in series to power DC buses with voltage rating higher than those available in the DCU range. Alternatively, series connection can be used to achieve higher currents than at higher voltage

### 12.1 Standard Output configuration

The standard configuration for all DC-UPS units is as follows.

A DCU unit connected to mains, with Battery output connected to a BBX unit (or customer battery pack) and Load output connected to the buffered DC load via the DC BUS.




Figure 12.1 – Standard Output configuration



#### NOTE

Protect the Load output. Design the load circuit to prevent high reverse return voltage (e.g., from a battery or a decelerating motor).

### 12.2 Redundancy Output configuration

Redundant power supply systems are required in applications which demand high reliability in operation. They require multiple DC-UPS units connected in parallel. As an example, 100% redundancy means that in case of one of the DC-UPS units becoming faulty, there will be another one able to meet 100% of load demand without interruption.

To do so, the DC-UPS units to be connected in parallel must be large enough to ensure that the total current requirement of all buffered loads can be fully met by one unit.

The DC-UPS units must be connected to the DC bus through a Decoupling Diodes module, like DCM20. See Figure 12.2.

Each DC-UPS is monitored by the Fault LED on the front. The Fault relay contact reports the alarm to a remote position or logic controller

As an advantage, 100% redundancy enables to hot-swap the failed DC-UPS and replace it with a new one without system down time.

### 12.3 Series Output configuration

More DCU units of the same type can be connected in series to provide higher voltage rating, as shown in Figure 12.3. However, please consider the following note:



#### NOTE

- In case of three-phase mains, if possible, connect each DC-UPS to different phases
- Use separate primary-side protection for each DC-UPS.




Figure 12.2 -Redundancy Output configuration




Figure 12.3 - Series Output configuration



**NOTE**

- Total output voltage must not exceed 150 Vdc
- Circuits with rated voltage above 72 Vdc are not SELV and can be dangerous if not provided with output earthing and earth leakage protection

## 13 Derating

### 13.1 Ambient Temperature Derating

The DC-UPS provides the  $I_n$  nominal current to the load up to +50 °C ambient temperature. At ambient temperatures above +50°C, output current must be decreased by 2.5 %/°C. When ambient temperature exceeds +70°C or in the event of thermal overload, the device does not switch off and continues to supply the load. Output current is automatically reduced to allow safe operation and protection of the DC-UPS

Once the device cools down, the output is enabled again.




Figure 13.1 – Ambient Temperature Derating

### 13.2 Elevation Derating

The DC-UPS can be installed and operated up to 2000 m elevation a.s.l. without any limitations and derating. When installed at locations above 2000 m, due to the lower air pressure and the reduced convection cooling associated, a derating will apply as by the chart below.




Figure 13.2 – Elevation Derating

## 14 Technical Data

### General description:

### DCU300M1224S

#### DCU Series - DC-UPS, AC to DC uninterruptable power systems for critical DC loads

All-in-One: Power supply + Battery charger + Back-up functions, all packaged in one box.

- Total power 300W
- Selectable Output Voltage, 12 Vdc or 24 Vdc
- Load-first, Dynamic Load/Battery power sharing
- Adjustable maximum battery charging current
- Suitable for backup of high inrush current DC loads
- Buffer time setting of load backup
- Universal charging output, selectable Battery Type
- Temperature compensation sensor via USB port
- Manual Battery start-up button with no mains
- Battery life test, automatic or via manual button
- Extensive BATTSAFE battery management firmware
- Full set of protection and monitoring functions
- Local monitoring and diagnostics on LEDs
- Remote alarms via 3 voltage-free relay contacts
- Communication via MODbus/CANbus data link

#### Input

Rated Input Voltage AC	115/230/277 Vac (range 85–305 Vac)	
Frequency Range	50/60 Hz (range 47- 440 Hz)	
Input Current (Typ.)	2.8 A (115 Vac), 1.4 A (230 Vac)	
Rated Input Voltage DC	110/220 Vdc (range 110–420 Vdc)	
Input Current DC (Typ.)	3.0 (110 Vdc), 1.5 A (220 Vdc)	
Inrush Current (Typ. Cold Start)	15 A max	
Setup, Rise Time Max	1 s	
Recommended External Fuse/MCB	10 A, curve C	

#### Load Output – Power Supply Mode – Mains ON & Battery OFF

Voltage, selectable by Dip Switch <sup>1</sup>	12 Vdc	24 Vdc
Rated Current ( $I_R$ )	15 A	10 A
Ripple / Noise <sup>2</sup>	80 mV <sub>pp</sub>	100 mV <sub>pp</sub>
Short Circuit Protection	yes	
Over Load Protection	Constant Current mode > 110% $I_R$	
Over Voltage Protection	35 Vdc	

#### Load Output – Standby Mode – Mains ON & Battery ON

Voltage Range, Automatic Set <sup>1</sup>	12-14.4 Vdc	24-28.8 Vdc
Max Continuous Current ( $I_R + I_{BATT}$ )	20 A	15 A
Max Current for 30 s	25 A	20 A
Max Current for 15 s	30 A	25 A
Max Current for 5 s	< 35 A	< 30 A

#### Load Output – Backup Mode – Mains OFF & Battery ON

Voltage Range, Automatic Set <sup>1</sup>	9.5-12 Vdc	18.5-24 Vdc
Max Continuous Current ( $I_R + I_{BATT}$ )	20 A	15 A
Max Current for 30 s	25 A	20 A
Max Current for 15 s	30 A	25 A
Max Current for 5 s	< 35 A	< 30 A
Time Buffering for Backup	30 s up to $\infty$	
Start from battery with no mains	Yes, on Push Button	
Quiescent current	< 90 mA	

#### Signal Output/Input

Standby / Backup	Change-over relay contact, M terminals
Common Fault	Change-over relay contact, F terminals
Rectifier failure	Change-over relay contact, S terminals
Full set of monitor and alarm visual signals	Flashing code on 3, Three-color LEDs
MODbus data link	Dual RJ45 connector

## Climatic Data

Operating Ambient Temperature (T <sub>A</sub> )	-25 up to +70°C
Relative Humidity, no condensation@25°C	max 95%
Storage Temperature	-40 up to +85°C
Cooling	Natural Convection

## General Data

Efficiency (Typ.)	>90%	>92%
Temperature Derating Factor <sup>1</sup>	2.5 %/°C , T <sub>A</sub> > 50°C	
Altitude Derating Factor <sup>1</sup>	0.5°C/100 m, above 2000 m	
Insulation Voltage (In/Out)	4 kVac	
Insulation Voltage (In/PE)	2 kVac	
Insulation Voltage (Out/PE)	500 Vdc	
Insulation Resistance (500 V)	> 100 MΩ	
Protection Class (EN/IEC 60529)	IP 20	
Pollution Degree Environment	2	
Dimensions (W x H x D)	80 x 130 x 126 mm	
Weight	0.9 kg	

## Norms and certifications - Conformity

Electrical Safety	Low Voltage Directive 2014/35/EU, 2014/35/UE as follow: EN60950-1, (UL60950-1, UL508, C22.2, EN60335-2-29, UL1236), EN IEC 62368-1:2014/AC:2015;
EMC Emission	EN55011 (CISPR11), EN55022 (CISPR22) Class B, EN61000-3-2,3
EMC Immunity	EN61000-4-2,3,4,5,6,8,11
Fire Detection and fire alarm systems	EN54-4
Battery chargers	IEC/EN 60335-2-29
Charging cycle	DIN41773
UL Pending	

## Battery Management

Rated Voltage	12 Vdc	24 Vdc
Charging Curve	3 stages (IUoU) + Recovery	
Charging Current setting (min/max)	1.5 A / 15.0 A	1 A / 10 A
Battery Type, selectable by Dip Switch	Vented & Sealed Lead Acid, AGM, Li-Io, Li-PoFe, NiCd	
Voltage max	14.75 Vdc	29.50 Vdc
Boost Voltage	14.4 Vdc	28.8 Vdc
Float Voltage, dip switch selectable	According to battery type	
Recovery Charge	2-10 Vdc	2-20 Vdc
Low Voltage Disconnect (LVD) Threshold	9.3 Vdc	18.5 Vdc
Low Voltage Alarm Threshold	11 Vdc	22 Vdc
Time Boost-Bulk Charge (Typ. IN)	min 5 s, max 15 h	
Temperature Compensation	SBS Smart Temperature Compensation probe (opt.)	
Boost voltage Enable/Disable	Local dip switch or Remote Link	
Protections	Reverse Polarity, Disconnected Battery Wrong Battery Voltage Sulphated Battery, Cell-In Short Circuit	
Battery Diagnostics		

Life Test	Automatic Every 2 h in Standby, Manual on Push Button
-----------	---

## Commercial Data

Weight per unit, including packing	1.0 kg
Dimensions per unit, including packing	85 x 138 x 134 mm
Volume per unit, including packing	0.0014 m <sup>3</sup>
Custom Tarif HS	85044055
Country of origin	Italy



**ARIS POWER Srl**  
Via Archimede, 10 - 37036 San Martino B.A. Verona - Italy  
+39 045 524579 - [www.arispower.com](http://www.arispower.com) - [admin@arispower.com](mailto:admin@arispower.com)